

AMENDMENT NO. 1 NOVEMBER 2020

TO

IS 335 : 2018 NEW INSULATING OILS — SPECIFICATION

(Fifth Revision)

(Page 4, Clause 6.5) — Substitute the last two sentences with the following:
‘DDF shall be measured in accordance with IS 16086 or IS 16840 at 90°C.
In case of dispute, IS 16840 at 90°C should be used.’

(Page 4, Table 2, Row (ix), Col (3)) — Substitute with the following:
‘IS 16086 or IS 16840’

(Page 8, Table 3, Row (vii), Col (3)) — Substitute with the following:
‘IEC 61620 or IEC 60247’

(Page 8, Table 3, Row (vii), Col (4)) — Substitute with the following:
‘IS 16086 or IS 16840’

(Page 9) — Substitute ‘IEC 60247 : 2004’ with the following:
‘IS 16840 : 2018’.